

## Glidden Michael

---

**From:** Kristin Kula <KKula@fvhd.org>  
**Sent:** Monday, January 05, 2015 10:43 AM  
**To:** Glidden Michael  
**Subject:** FW: talcott

---

**From:** Kristin Kula  
**Sent:** Monday, December 08, 2014 12:07 PM  
**To:** brian denno ([brian.denno@gmail.com](mailto:brian.denno@gmail.com))  
**Subject:** talcott

Hi Brian,

I have a few comments on this plan.

1. Need well locations
2. System on lot 3 needs to follow the contours
3. Additional test pits (can be hand dug) and possibly percs are needed on lot 1 at north end of system and downslope of system
4. An additional test pit is needed downslope of system on lot 5

Thanks,  
Kristin

**Kristin Kula**  
*Registered Sanitarian*  
Farmington Valley Health District  
95 River Rd. Suite C  
Canton, CT 06019  
O-860-352-2333 | C-860-989-9584 | F-860-352-2542  
[kkula@fvhd.org](mailto:kkula@fvhd.org)



Farmington Valley Health District

*Mission: We strive to **prevent** disease outbreaks and conditions that give rise to poor health, **promote** health programs and policies that support good health, and **protect** members of our community from health threats—both the everyday and the exceptional.*

**ExchangeDefender Message Security: [Check Authenticity](#)**