



Town of Simsbury

66 TOWN FOREST ROAD, WEST SIMSBURY, CONNECTICUT 06092
Phone (860) 658-3222 Fax (860) 408-5416 E-mail troy@simsbury-ct.gov

~ Thomas J. Roy, P.E. – Director of Public Works ~

ADDENDUM No. 1

February 16, 2023

TOWN OF SIMSBURY

DPW

Request for Proposals

FOR

FOR ON-CALL, HVAC PREVENTIVE, AND CORRECTIVE

MAINTENANCE SERVICES

The information provided in this Addendum is intended to supplement and clarify the existing information in the ITB and is not to replace any part of the specification unless clearly indicated as such.

This Addendum No. 1 is to provide prospective bidders with a list of the filters associated with the equipment covered by this RFP.

DOCUMENTS ADDED AS A RESULT OF ADDENDUM 1

- HVAC Filters List

Bidders should include this addendum as part of their bid submission.

END

HVAC Equipment Filter List

Town Hall Equipment filter list

1. AHU 1
 - a. Motor, Gold Century
 - i. Part 6-322467-02
 - ii. 5 HP, 3 Phase 60 HZ 200V-208V
 - b. Belt Bp68
 - c. Filters 8- 20X25X2 Merv 8
2. AHU2
 - a. Motor, Leeson
 - i. C145T17DB2C
 - ii. 2 HP, 3 Phase, 60 Hz, 208-230V
 - b. Belt A51
 - c. Filters 4- 20X25X2 Merv 8
3. Electric Fan 1
 - a. Motor Baldor Supper E
 - i. CAT# EM3558T-8
 - ii. Spec # 35A001TG7361
 - iii. 2 HP 3 Phase, 60 Hz 200
 - b. Belt A-48
4. Electric Fan 2
 - a. .75 HP, 3Phase, 60Hz, 200 V
 - b. Belt 4L420
5. RTU 1
 - a. Aaron 5847
 - b. Motor Super E
 - i. EM 3311T-B, 7 ½ HP
 - c. Condenser Fan Motor Emmerson K55HKMSD8679
 - i. ¾ HP
 - d. Filters 6- 16X20X2 Merv 8
6. RTU 2
 - a. Aaron 58478
 - b. Motor Baldor Super E EM321BT-B
 - c. Belt Bx63
 - d. Filters 6- 16X20X2 Merv 8

7. RTU 3
 - a. Aaron 58479
 - b. Motor EM3311T-B, 7 ½ HP
 - c. Belt Bx70
 - d. Filters 6- 16X20X2 Merv 8
8. RTU 4
 - a. Aaron 58476
 - b. Motor EM3311T-B
 - c. Belt Bx 70
 - d. Filters 6- 16X20X2 Merv 8
9. RTU 5
 - a. Aaron 58475
 - b. Motor EFM3157T-8
 - c. Belt Bx 46
 - d. Filters 4- 16X20X2 Merv 8
10. RTU 6
 - a. Aaron 58475
 - b. Motor EFM 3157T-8
 - c. Belt Bx46
 - d. Filters 4- 16X20X2 Merv 8

Library HVAC equipment list

1. AHU 1
 - a. Motor Ge Energy Saver 5KS213ATE205A
 - b. Belt Bx 58
 - c. Filters 4- 20X25X2 Merv 8, 2- 20X20X2 Merv 8
2. AHU 2
 - a. Motor 5KS184ATE205A
 - b. Belt Bx 35
 - c. Filters 4- 16X24X2
3. EAHU
 - a. Motor A.O. Smith 7-850024-01-oj
 - b. Belts 2- Bx95
 - c. Filters 20- 20X25X2
4. RTU1
 - a. Motor AO Smith 7-850095-01-J3
 - b. Belts 2- Bx38

- c. Filters 9- 20X25X2

Eno Memorial Hall

- 1. AHU 1
 - a. Motor 4GZA7 Dayton
 - b. Belt BX46
 - c. Filters 6-20X20X2