



Town of Simsbury

933 HOPMEADOW STREET

SIMSBURY, CONNECTICUT

ADDENDUM No. 1

September 2, 2022

REQUEST FOR PROPOSAL

PROFESSIONAL DESIGN SERVICES

WATER POLLUTION CONTROL FACILITY PRIMARY CLARIFIER RESTORATION

The information provided in this Addendum is intended to supplement and clarify the existing information in the Request for Proposal and is not to replace any part of the specification unless clearly indicated as such.

Below are responses to questions we received to date:

Question: Clarify requirement for Clean Water Fund Application.

Response: **Preparation of Clean water Fund Application is not required and is removed from this RFP.**

Question: Are you looking for a detailed concrete inspection to confirm (i.e. peer review) the report provided?

Response: **Structural conditions may have changed in the years since the inspection was complete. Additional structural evaluation is anticipated to accurately determine the current structural condition of the tanks.**

Question: Are you looking for a detailed process equipment, architectural, electrical inspection to determine what is needed to safely and reliably place the clarifiers back in operation.

Response: **This RFP is for structural repairs to the Clarifiers only. No equipment, electrical or architectural inspections are required.**

Question: Clarification of Phase 5 Construction Engineering (CE) services is requested.

Response: **Construction Engineering services shall include the following:**

- **Schedule Preconstruction Meeting with Town & Contractor.**
- **Review of submittals, shop drawings, certificates of compliance.**
- **Field observation of work in progress with reports.**
- **Coordination with testing agencies as applicable.**
- **Review and coordination of Contractor's Applications for payment.**

END