



Town of Simsbury

933 HOPMEADOW STREET

P.O. BOX 495

SIMSBURY, CONNECTICUT 06070

Jerome F. Shea – Town Engineer

ADDENDUM #2

**Invitation to Bid
Portable Generator Set
Simsbury, Connecticut**

July 11, 2014

This addendum form is part of the request for proposals document and modifies the original document as noted below. Acknowledge receipt of addenda on the Bid Proposal Form. Failure to do so may subject the bidder to disqualification.

1. Revise specification section 269000-7. Equipment, paragraph 7.1 to be as follows:

7.1 The generator set shall be a Kohler Model # 275REOZJE with a LSA462L9 alternator, or acceptable equivalent. It shall provide 243kW/304kVA when operating at 120/208 volts, 60 Hz, three phase, or 277/480 volt, 60 Hz, three phase. The generator set shall be capable of a Standby 27°C rating. The generator set shall be a KOHLER or acceptable equivalent by listed manufacturers. The basis of design generator set described herein is KOHLER, and it is with the price of this equipment that the contractor of this section shall enter with his proposal. If the contractor proposes equivalent equipment, it shall be submitted in a separate document. All additional costs associated with re-engineering and mechanical & electrical modifications to the installation will be at the contractor's expense. The contractor must also supply the details listed below with his equivalent proposal.

END OF ADDENDUM NO. 2

Telephone (860) 658-3260
Facsimile (860) 658-3205

jshea@simsbury-ct.gov
www.simsbury-ct.gov

An Equal Opportunity Employer
8:30 – 7:00 Monday
8:30 - 4:30 Tuesday through
Thursday
8:30 – 1:00 Friday