



Town of Simsbury

66 TOWN FOREST ROAD, SIMSBURY, CONNECTICUT 06070
Phone (860) 658-3222 Fax (860) 408-5416 E-mail troy@simsbury-ct.gov

~ Thomas J. Roy, P.E. – Director of Public Works ~

ADDENDUM No. 1

TOWN OF SIMSBURY

Invitation to Bid

FOR

EAST WEATOGUE STREET DRAINAGE IMPROVEMENTS

The information provided in this Addendum is intended to supplement and clarify the existing information in the Invitation to Bid and is not to replace any part of the specification unless clearly indicated as such.

Below are responses to questions we received during the pre-bid conference on March 29, 2018:

Question: Is there any known rock present?

Response: **It is assumed that there is minimal rock within the limits of construction. If rock is encountered which needs to be removed, the Town will pay on the basis of time and materials.**

Question: Are the removal of tagged trees included in this project?

Response: **The removal of tagged trees is not included in the scope of work for this project. The Town will remove these trees before construction starts, stumps to remain.**

Question: What is the purpose of the stone pad?

Response: **In the event of a high overflow, storm water will overflow from proposed catch basin #4 and run off into the field next to house #137. The stone is to slow down this flow and help reduce erosion.**

Question: Can the road be closed during construction?

Response: **The road can be closed on a daily basis, and re-opened at the end of the day. The road must remain open to Police, Fire, EMS, school busses and residents who live within the limits of the project. The contractor shall submit a traffic control plan to the Town, and handle all coordination with the Simsbury Police Department and Bus Company.**

Proposals are due Thursday, April 5th at 10:00am in the Office of the Finance Director.

END