



Town of Simsbury

66 TOWN FOREST ROAD, WEST SIMSBURY, CONNECTICUT 06092
Phone (860) 658-3222 Fax (860) 408-5416

ADDENDUM No. 1

TOWN OF SIMSBURY

Invitation to Bid

FOR

Simsbury Center Sidewalk Improvements

The information provided in this Addendum is intended to supplement and clarify the existing information in the ITB and is not to replace any part of the specification unless clearly indicated as such.

Below are responses to questions we received to date:

Question: On the 5th page of the invitation to bid, it states that a bid bond and performance bond are not applicable; however on page 14 of the General Conditions (under Contract Security) it states that both a performance bond and payment bond, in penal sums, should be equal to the amount of the contract price. Can you confirm which is correct?

Response: **The Invitation to Bid is correct. Contract language relating to bonds will be stricken.**

Question: After doing a site walk-thru and reviewing the bid form, it calls for a price for bituminous concrete curbing (estimated quantity of 70 LF). Can you advise where on the site the bituminous concrete curbing will go?

Response: **It is anticipated that the existing bituminous curb at the bottom of Phelps Lane, east of the Historical Society parking lot entrance, will need to be replaced after the 23 LF of concrete sidewalk is installed and necessary grading complete.**

Question: At the location on Jim Gallagher Way, the section calls for removal of existing bituminous concrete sidewalk, and the installation of new sidewalk (at the bottom of Jim Gallagher Way – smaller section). There is existing bituminous curbing against the existing bituminous sidewalk. Will curbing also be replaced at this location?

Response: **The existing bituminous concrete sidewalk and curb shall be removed and new 5" Concrete Sidewalk and Curb Monolithic installed.**